



# FIRELAB

## CERTIFICATE

This is to certify that the

**FIRE DOOR/RB-DOOR**

(2100 mm x 800mm Single leaf, Steel clad Security Door with steel frame, RB Lock and 3 Hinges)

achieved a Classification

of

**Class D Door Assembly (No Insulation)**

Stability (R), and Integrity (E)

(R 120, E 120)

For use as Security Fire Door

in accordance with

**SANS 1253:2016**

(Fire Resistance & Mechanical testing)

Signed:

Report Number: **FTC 19/127**

Report validity: **July 2024**

(For door assembly detail and more information refer to report number FTC 19/127)

Reg no: 2005/087037/23 • Tel: +27 12 349 2929 • info@firelab.co.za

**NATIONAL SAFE CO GAUTENG PTY LTD**  
11 CLEVELAND ROAD, CLEVELAND, JOHANNESBURG • +27 11 902 4108

